

information no less than 10 working days prior to the meeting; full name; gender; date/place of birth; citizenship; visa/green card information (number, type, expiration date); passport information (number, country, telephone); employer/affiliation information (name of institution, address, country, telephone); title/position of attendee. To expedite admittance, attendees with U.S. citizenship can provide identifying information 3 working days in advance by contacting Charlene Williams at (202) 358-2183, or fax: (202) 358-4336.

Patricia D. Rausch,

*Advisory Committee Management Officer,
National Aeronautics and Space
Administration.*

[FR Doc. 2012-3920 Filed 2-17-12; 8:45 am]

BILLING CODE 7510-13-P

NUCLEAR REGULATORY COMMISSION

[NRC-2012-0038]

Biweekly Notice; Applications and Amendments to Facility Operating Licenses Involving No Significant Hazards Considerations

Background

Pursuant to Section 189a.(2) of the Atomic Energy Act of 1954, as amended (the Act), the U.S. Nuclear Regulatory Commission (the Commission or NRC) is publishing this regular biweekly notice. The Act requires the Commission publish notice of any amendments issued, or proposed to be issued and grants the Commission the authority to issue and make immediately effective any amendment to an operating license upon a determination by the Commission that such amendment involves no significant hazards consideration, notwithstanding the pendency before the Commission of a request for a hearing from any person.

This biweekly notice includes all notices of amendments issued, or proposed to be issued from January 26, 2012 to February 8, 2012. The last biweekly notice was published on February 7, 2012 (77 FR 6144).

ADDRESSES: You may access information and comment submissions related to this document, which the NRC possesses and is publicly-available, by searching on <http://www.regulations.gov> under Docket ID NRC-2012-0038. You may submit comments by the following methods:

- *Federal Rulemaking Web Site:* Go to <http://www.regulations.gov> and search for Docket ID NRC-2012-0038. Address

questions about NRC dockets to Carol Gallagher; telephone: 301-492-3668; email: Carol.Gallagher@nrc.gov.

- *Mail comments to:* Cindy Bladey, Chief, Rules, Announcements, and Directives Branch (RADB), Office of Administration, Mail Stop: TWB-05-B01M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001.

- *Fax comments to:* RADB at 301-492-3446.

For additional direction on accessing information and submitting comments, see "Accessing Information and Submitting Comments" in the **SUPPLEMENTARY INFORMATION** section of this document.

SUPPLEMENTARY INFORMATION:

Accessing Information and Submitting Comments

A. Accessing Information

Please refer to Docket ID NRC-2012-0038 when contacting the NRC about the availability of information regarding this document. You may access information related to this document, which the NRC possesses and is publicly-available, by the following methods:

- *Federal Rulemaking Web Site:* Go to <http://www.regulations.gov> and search for Docket NRC-2012-0038.

- *NRC's Agencywide Documents Access and Management System (ADAMS):* You may access publicly-available documents online in the NRC Library at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select "ADAMS Public Documents" and then select "Begin Web-based ADAMS Search." For problems with ADAMS, please contact the NRC's Public Document Room (PDR) Reference staff at 1-800-397-4209, 301-415-4737, or by email to pdr.resource@nrc.gov.

- *NRC's PDR:* You may examine and purchase copies of public documents at the NRC's PDR, Room O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

B. Submitting Comments

Please include Docket ID NRC-2012-0038 in the subject line of your comment submission, in order to ensure that the NRC is able to make your comment submission available to the public in this docket.

The NRC cautions you not to include identifying or contact information in comment submissions that you do not want to be publicly disclosed. The NRC posts all comment submissions at <http://www.regulations.gov> as well as entering the comment submissions into ADAMS, and the NRC does not edit

comment submissions to remove identifying or contact information.

If you are requesting or aggregating comments from other persons for submission to the NRC, then you should inform those persons not to include identifying or contact information in their comment submissions that they do not want to be publicly disclosed. Your request should state that the NRC will not edit comment submissions to remove such information before making the comment submissions available to the public or entering the comment submissions into ADAMS.

Notice of Consideration of Issuance of Amendments to Facility Operating Licenses, Proposed No Significant Hazards Consideration Determination and Opportunity for a Hearing

The Commission has made a proposed determination that the following amendment requests involve no significant hazards consideration. Under the Commission's regulations in Title 10 of the Code of Federal Regulations (10 CFR) 50.92, this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. The basis for this proposed determination for each amendment request is shown below.

The Commission is seeking public comments on this proposed determination. Any comments received within 30 days after the date of publication of this notice will be considered in making any final determination.

Normally, the Commission will not issue the amendment until the expiration of 60 days after the date of publication of this notice. The Commission may issue the license amendment before expiration of the 60-day period provided that its final determination is that the amendment involves no significant hazards consideration. In addition, the Commission may issue the amendment prior to the expiration of the 30-day comment period should circumstances change during the 30-day comment period such that failure to act in a timely way would result, for example in derating or shutdown of the facility. Should the Commission take action prior to the expiration of either the comment period or the notice period, it will publish in the **Federal Register** a notice of issuance. Should the

Commission make a final No Significant Hazards Consideration Determination, then any hearing will take place after issuance. The Commission expects that the need to take this action will occur very infrequently.

Within 60 days after the date of publication of this notice, any person(s) whose interest may be affected by this action may file a request for a hearing and a petition to intervene with respect to issuance of the amendment to the subject facility operating license. Requests for a hearing and a petition for leave to intervene shall be filed in accordance with the Commission's "Rules of Practice for Domestic Licensing Proceedings" in 10 CFR Part 2. Interested person(s) should consult a current copy of 10 CFR 2.309, which is available at the NRC's PDR, located at One White Flint North, Room O1-F21, 11555 Rockville Pike (first floor), Rockville, Maryland 20852. The NRC regulations are accessible electronically from the NRC Library on the NRC Web site at <http://www.nrc.gov/reading-rm/doc-collections/cfr/>. If a request for a hearing or petition for leave to intervene is filed by the above date, the Commission or a presiding officer designated by the Commission or by the Chief Administrative Judge of the Atomic Safety and Licensing Board Panel, will rule on the request and/or petition; and the Secretary or the Chief Administrative Judge of the Atomic Safety and Licensing Board will issue a notice of a hearing or an appropriate order.

As required by 10 CFR 2.309, a petition for leave to intervene shall set forth with particularity the interest of the petitioner in the proceeding, and how that interest may be affected by the results of the proceeding. The petition should specifically explain the reasons why intervention should be permitted with particular reference to the following general requirements: (1) The name, address, and telephone number of the requestor or petitioner; (2) the nature of the requestor's/petitioner's right under the Act to be made a party to the proceeding; (3) the nature and extent of the requestor's/petitioner's property, financial, or other interest in the proceeding; and (4) the possible effect of any decision or order which may be entered in the proceeding on the requestor's/petitioner's interest. The petition must also identify the specific contentions which the requestor/petitioner seeks to have litigated at the proceeding.

Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the requestor/petitioner shall

provide a brief explanation of the bases for the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the requestor/petitioner intends to rely in proving the contention at the hearing. The requestor/petitioner must also provide references to those specific sources and documents of which the petitioner is aware and on which the requestor/petitioner intends to rely to establish those facts or expert opinion. The petition must include sufficient information to show that a genuine dispute exists with the applicant on a material issue of law or fact. Contentions shall be limited to matters within the scope of the amendment under consideration. The contention must be one which, if proven, would entitle the requestor/petitioner to relief. A requestor/petitioner who fails to satisfy these requirements with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene, and have the opportunity to participate fully in the conduct of the hearing.

If a hearing is requested, the Commission will make a final determination on the issue of no significant hazards consideration. The final determination will serve to decide when the hearing is held. If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately effective, notwithstanding the request for a hearing. Any hearing held would take place after issuance of the amendment. If the final determination is that the amendment request involves a significant hazards consideration, then any hearing held would take place before the issuance of any amendment.

All documents filed in NRC adjudicatory proceedings, including a request for hearing, a petition for leave to intervene, any motion or other document filed in the proceeding prior to the submission of a request for hearing or petition to intervene, and documents filed by interested governmental entities participating under 10 CFR 2.315(c), must be filed in accordance with the NRC E-Filing rule (72 FR 49139, August 28, 2007). The E-Filing process requires participants to submit and serve all adjudicatory documents over the Internet, or in some cases to mail copies on electronic storage media. Participants may not submit paper copies of their filings

unless they seek an exemption in accordance with the procedures described below.

To comply with the procedural requirements of E-Filing, at least 10 days prior to the filing deadline, the participant should contact the Office of the Secretary by email at hearing.docket@nrc.gov, or by telephone at (301) 415-1677, to request (1) a digital identification (ID) certificate, which allows the participant (or its counsel or representative) to digitally sign documents and access the E-Submittal server for any proceeding in which it is participating; and (2) advise the Secretary that the participant will be submitting a request or petition for hearing (even in instances in which the participant, or its counsel or representative, already holds an NRC-issued digital ID certificate). Based upon this information, the Secretary will establish an electronic docket for the hearing in this proceeding if the Secretary has not already established an electronic docket.

Information about applying for a digital ID certificate is available on the NRC's public Web site at <http://www.nrc.gov/site-help/e-submittals/apply-certificates.html>. System requirements for accessing the E-Submittal server are detailed in the NRC's "Guidance for Electronic Submission," which is available on the agency's public Web site at <http://www.nrc.gov/site-help/e-submittals.html>. Participants may attempt to use other software not listed on the Web site, but should note that the NRC's E-Filing system does not support unlisted software, and the NRC Meta System Help Desk will not be able to offer assistance in using unlisted software.

If a participant is electronically submitting a document to the NRC in accordance with the E-Filing rule, the participant must file the document using the NRC's online, Web-based submission form. In order to serve documents through the Electronic Information Exchange System, users will be required to install a Web browser plug-in from the NRC Web site. Further information on the Web-based submission form, including the installation of the Web browser plug-in, is available on the NRC's public Web site at <http://www.nrc.gov/site-help/e-submittals.html>.

Once a participant has obtained a digital ID certificate and a docket has been created, the participant can then submit a request for hearing or petition for leave to intervene. Submissions should be in Portable Document Format (PDF) in accordance with the NRC

guidance available on the NRC's public Web site at <http://www.nrc.gov/site-help/e-submittals.html>. A filing is considered complete at the time the documents are submitted through the NRC's E-Filing system. To be timely, an electronic filing must be submitted to the E-Filing system no later than 11:59 p.m. Eastern Time on the due date. Upon receipt of a transmission, the E-Filing system time-stamps the document and sends the submitter an email notice confirming receipt of the document. The E-Filing system also distributes an email notice that provides access to the document to the NRC's Office of the General Counsel and any others who have advised the Office of the Secretary that they wish to participate in the proceeding, so that the filer need not serve the documents on those participants separately. Therefore, applicants and other participants (or their counsel or representative) must apply for and receive a digital ID certificate before a hearing request/petition to intervene is filed so that they can obtain access to the document via the E-Filing system.

A person filing electronically using the agency's adjudicatory E-Filing system may seek assistance by contacting the NRC Meta System Help Desk through the "Contact Us" link located on the NRC's Web site at <http://www.nrc.gov/site-help/e-submittals.html>, by email at MSHD.Resource@nrc.gov, or by a toll-free call at 1-(866) 672-7640. The NRC Meta System Help Desk is available between 8 a.m. and 8 p.m., Eastern Time, Monday through Friday, excluding government holidays.

Participants who believe that they have a good cause for not submitting documents electronically must file an exemption request, in accordance with 10 CFR 2.302(g), with their initial paper filing requesting authorization to continue to submit documents in paper format. Such filings must be submitted by: (1) First class mail addressed to the Office of the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Rulemaking and Adjudications Staff; or (2) courier, express mail, or expedited delivery service to the Office of the Secretary, Sixteenth Floor, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852, Attention: Rulemaking and Adjudications Staff. Participants filing a document in this manner are responsible for serving the document on all other participants. Filing is considered complete by first-class mail as of the time of deposit in the mail, or by courier, express mail, or expedited

delivery service upon depositing the document with the provider of the service. A presiding officer, having granted an exemption request from using E-Filing, may require a participant or party to use E-Filing if the presiding officer subsequently determines that the reason for granting the exemption from use of E-Filing no longer exists.

Documents submitted in adjudicatory proceedings will appear in the NRC's electronic hearing docket which is available to the public at <http://ehd1.nrc.gov/ehd/>, unless excluded pursuant to an order of the Commission, or the presiding officer. Participants are requested not to include personal privacy information, such as social security numbers, home addresses, or home phone numbers in their filings, unless an NRC regulation or other law requires submission of such information. With respect to copyrighted works, except for limited excerpts that serve the purpose of the adjudicatory filings and would constitute a Fair Use application, participants are requested not to include copyrighted materials in their submission.

Petitions for leave to intervene must be filed no later than 60 days from the date of publication of this notice. Non-timely filings will not be entertained absent a determination by the presiding officer that the petition or request should be granted or the contentions should be admitted, based on a balancing of the factors specified in 10 CFR 2.309(c)(1)(i)-(viii).

For further details with respect to this license amendment application, see the application for amendment which is available for public inspection at the NRC's PDR, located at One White Flint North, Room O1-F21, 11555 Rockville Pike (first floor), Rockville, Maryland 20852. Publicly available documents created or received at the NRC are accessible electronically through ADAMS in the NRC Library at <http://www.nrc.gov/reading-rm/adams.html>. Persons who do not have access to ADAMS or who encounter problems in accessing the documents located in ADAMS, should contact the NRC's PDR Reference staff at 1-(800) 397-4209, (301) 415-4737, or by email to pdr.resource@nrc.gov.

Southern Nuclear Operating Company, Inc., Docket Nos. 50-348 and 50-364, Joseph M. Farley Nuclear Plant, Units 1 and 2, Houston County, Alabama

Date of amendment request: January 12, 2012.

Description of amendment request: The proposed amendments would extend the Reactor Coolant Pump (RCP)

motor flywheel examination frequency from the currently approved 10-year examination frequency to an interval not to exceed 20 years. The changes are consistent with the Industry/Technical Specification Task Force (TSTF) Standard Technical Specification Change Traveler, TSTF-421-A, "Revision to RCP Flywheel Inspection Program (WCAP-15666)." The availability of this TS improvement was announced in the **Federal Register** on October 22, 2003 (68 FR 60422), as part of the Consolidated Line Item Improvement Process (CLIP).

The NRC staff issued a notice of availability of a model safety evaluation and model no significant hazards consideration (NSHC) determination for referencing in license amendment applications in the **Federal Register** on June 24, 2003 (68 FR 37590). The licensee affirmed the applicability of the model NSHC determination in its application dated May 21, 2004.

Basis for proposed no significant hazards consideration determination: As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

Criterion 1—The Proposed Change Does Not Involve a Significant Increase in the Probability or Consequences of an Accident Previously Evaluated

The proposed change to the RCP flywheel examination frequency does not change the response of the plant to any accidents. The RCP will remain highly reliable and the proposed change will not result in a significant increase in the risk of plant operation. Given the extremely low failure probabilities for the RCP motor flywheel during normal and accident conditions, the extremely low probability of a loss-of-coolant accident (LOCA) with loss of offsite power (LOOP), and assuming a conditional core damage probability (CCDP) of 1.0 (complete failure of safety systems), the core damage frequency (CDF) and change in risk would still not exceed the NRC's acceptance guidelines contained in Regulatory Guide (RG) 1.174 ($<1.0E-6$ per year). Moreover, considering the uncertainties involved in this evaluation, the risk associated with the postulated failure of an RCP motor flywheel is significantly low. Even if all four RCP motor flywheels are considered in the bounding plant configuration case, the risk is still acceptably low.

The proposed change does not adversely affect accident initiators or precursors, nor alter the design assumptions, conditions, or configuration of the facility, or the manner in which the plant is operated and maintained; alter or prevent the ability of structures, systems, and components (SSCs) from performing their intended function to mitigate the consequences of an initiating event within the assumed acceptance limits; or affect the source term, containment

isolation, or radiological release assumptions used in evaluating the radiological consequences of an accident previously evaluated. Further, the proposed change does not increase the type or amount of radioactive effluent that may be released offsite, nor significantly increase individual or cumulative occupational/public radiation exposure. The proposed change is consistent with the safety analysis assumptions and resultant consequences.

Therefore, the proposed change does not involve a significant increase in the probability or consequences of an accident previously evaluated.

Criterion 2—The Proposed Change Does Not Create the Possibility of a New or Different Kind of Accident From Any Accident Previously Evaluated

The proposed change in flywheel inspection frequency does not involve any change in the design or operation of the RCP. Nor does the change to examination frequency affect any existing accident scenarios, or create any new or different accident scenarios. Further, the change does not involve a physical alteration of the plant (i.e., no new or different type of equipment will be installed) or alter the methods governing normal plant operation. In addition, the change does not impose any new or different requirements or eliminate any existing requirements, and does not alter any assumptions made in the safety analysis. The proposed change is consistent with the safety analysis assumptions and current plant operating practice.

Therefore, the proposed change does not create the possibility of a new or different kind of accident from any accident previously evaluated.

Criterion 3—The Proposed Change Does Not Involve a Significant Reduction in a Margin of Safety

The proposed change does not alter the manner in which safety limits, limiting safety system settings, or limiting conditions for operation are determined. The safety analysis acceptance criteria are not impacted by this change. The proposed change will not result in plant operation in a configuration outside of the design basis. The calculated impact on risk is insignificant and meets the acceptance criteria contained in RG 1.174. There are no significant mechanisms for inservice degradation of the RCP flywheel.

Therefore, the proposed change does not involve a significant reduction in a margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

Attorney for licensee: M. Stanford Blanton, Esq., Balch and Bingham, Post Office Box 306, 1710 Sixth Avenue North, Birmingham, Alabama 35201.

NRC Branch Chief: Nancy Salgado.

Virginia Electric and Power Company, Docket Nos. 50–280 and 50–281, Surry Power Station, Units 1 and 2, Surry County, Virginia and 50–338 and 50–339, North Anna Power Station Units 1 and 2, Mineral, Virginia

Date of amendment request: October 6, 2011.

Description of amendment request: To change the Emergency Action Levels (EALs) for North Anna Power Station (NAPS) and Surry Power Station (SPS). Several changes are proposed to incorporate lessons learned from the safety related breaker fire that occurred at NAPS on April 22, 2009 (Ref. NRC Event Notification Report 45013). The proposed changes are briefly summarized as follows: (1) Revise the definition of “Affecting Safe Shutdown” in the EAL Technical Basis Documents to specifically describe how this applies to NAPS and SPS; (2) revise applicable Hazards EALs to incorporate the intent of the revised definition for “Affecting Safe Shutdown”; in addition, the main dam is added to the Initiating Condition (IC) for HA1 for NAPS and the low level intake structure is added to the IC for HA1 for SPS; (3) changing the IC for HA2 and HA3 to replace “a safe shutdown area” with “any Table H–1 Area”; and (4) revise applicable System Malfunctions EAL to include a 15-minute threshold for RCS leaks.

Basis for proposed no significant hazards consideration determination: As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Does the proposed change involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No.

These changes affect the North Anna and Surry Power Station Emergency Action Levels, but do not alter any of the requirements of the Operating License or the Technical Specifications. The proposed changes do not modify any plant equipment and do not impact any failure modes that could lead to an accident. Additionally, the proposed changes have no effect on the consequences of any analyzed accident since the changes do not affect any equipment related to accident mitigation. Based on this discussion, the proposed amendment does not increase the probability or consequence of an accident previously evaluated.

2. Does the proposed change create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No.

These changes affect the North Anna and Surry Power Station Emergency Action Levels, but do not alter any of the requirements of the Operating License or the

Technical Specifications. They do not modify any plant equipment and there is no impact on the capability of the existing equipment to perform their intended functions. No system setpoints are being modified. No new failure modes are introduced by the proposed changes. The proposed amendment, does not introduce any accident initiators or malfunctions that would cause a new or different kind of accident.

Therefore, the proposed amendment does not create the possibility of a new or different kind of accident from any accident previously evaluated.

3. Does the proposed change involve a significant reduction in a margin of safety?

Response: No.

These changes affect the North Anna and Surry Power Station Emergency Action Levels, but do not alter any of the requirements of the Operating License or the Technical Specifications. The proposed changes do not affect any of the assumptions used in the accident analysis, nor do they affect any operability requirements for equipment important to plant safety.

Therefore, the proposed changes will not result in a significant reduction in the margin of safety in operation of the facility as discussed in this license amendment request.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

Attorney for licensee: Lillian M. Cuoco, Esq., Senior Counsel, Dominion Resources Services, Inc., 120 Tredegar St., RS–2, Richmond, VA 23219.

NRC Branch Chief: Nancy Salgado.

Notice of Issuance of Amendments to Facility Operating Licenses

During the period since publication of the last biweekly notice, the Commission has issued the following amendments. The Commission has determined for each of these amendments that the application complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations. The Commission has made appropriate findings as required by the Act and the Commission's rules and regulations in 10 CFR chapter I, which are set forth in the license amendment.

Notice of Consideration of Issuance of Amendment to Facility Operating License, Proposed No Significant Hazards Consideration Determination, and Opportunity for A Hearing in connection with these actions was published in the **Federal Register** as indicated.

Unless otherwise indicated, the Commission has determined that these

amendments satisfy the criteria for categorical exclusion in accordance with 10 CFR 51.22. Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared for these amendments. If the Commission has prepared an environmental assessment under the special circumstances provision in 10 CFR 51.22(b) and has made a determination based on that assessment, it is so indicated.

For further details with respect to the action see (1) the applications for amendment, (2) the amendment, and (3) the Commission's related letter, Safety Evaluation and/or Environmental Assessment as indicated. All of these items are available for public inspection at the NRC's Public Document Room (PDR), located at One White Flint North, Room O1-F21, 11555 Rockville Pike (first floor), Rockville, Maryland 20852. Publicly available documents created or received at the NRC are accessible electronically through the Agencywide Documents Access and Management System (ADAMS) in the NRC Library at <http://www.nrc.gov/reading-rm/adams.html>. If you do not have access to ADAMS or if there are problems in accessing the documents located in ADAMS, contact the NRC's PDR Reference staff at 1-(800) 397-4209, (301) 415-4737 or by email to pdr.resource@nrc.gov.

Entergy Nuclear Operations, Inc., Docket No. 50-255, Palisades Nuclear Plant, Van Buren County, Michigan

Date of application for amendment: January 31, 2011, supplemented by letter dated October 11, 2011.

Brief description of amendment: The amendment modifies the Spent Fuel Pool (SFP) storage requirements in PNP Technical Specifications (TS) Section 3.7.16 by revising a limiting condition for operation (LCO) for Region I fuel and non-fissile bearing component storage and by inserting tables containing spent fuel minimum burn-up for Regions 1B, 1C, 1D, and 1E; and also modifies the Region I fuel storage criticality requirements, and design features in TS section 4.3, by describing revised requirements for Regions 1B and 1E and adding requirements for new Regions 1C and 1D.

Date of issuance: January 27, 2012.

Effective date: As of the date of issuance and shall be implemented within 60 days of issuance.

Amendment No.: 246.

Facility Operating License No. DPR-20: Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: May 10, 2011 (76 FR 27096).

The supplemental letter contained clarifying information and did not change the initial no significant hazards consideration determination, and did not expand the scope of the original **Federal Register** notice.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 27, 2012.

No significant hazards consideration comments received: No.

Nebraska Public Power District, Docket No. 50-298, Cooper Nuclear Station, Nemaha County, Nebraska

Date of amendment request: January 5, 2011, as supplemented by letters dated October 6 and 18, 2011.

Brief description of amendment: The amendment revised Technical Specification (TS) 3.4.3, "Safety/Relief Valves (SRVs) and Safety Valves (SVs)." The original proposed TS changes would have revised the required number of SRVs required to be operable for overpressure protection and Anticipated Transient without Scram from eight to five. By letter dated October 6, 2011, the licensee revised its submittal by changing the proposed required number of SRVs to be operable from eight to seven.

Date of issuance: January 31, 2012.

Effective date: As of the date of issuance and shall be implemented within 60 days of issuance.

Amendment No.: 240.

Renewed Facility Operating License No. DPR-46: Amendment revised the Facility Operating License and Technical Specifications.

Date of initial notice in Federal Register: November 1, 2011 (76 FR 67488).

The supplemental letters dated October 6 and 18, 2011, provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination as published in the **Federal Register**.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 31, 2012.

No significant hazards consideration comments received: No.

NextEra Energy Point Beach, LLC, Docket Nos. 50-266 and 50-301, Point Beach Nuclear Plant, Units 1 and 2, Town of Two Creeks, Manitowoc County, Wisconsin

Date of application for amendments: March 23, 2011.

Brief description of amendments: The amendments replace non-conservative

values for five operating limits in the Technical Specifications with more conservative values that incorporate measurement uncertainty. Additionally, one of the operating limits will replace a tank volume expressed in cubic feet with a volume expressed in percent level to allow plant operators to directly verify the technical specification limit based on direct instrument readings.

Date of issuance: January 30, 2012.

Effective date: As of the date of issuance and shall be implemented within 60 days.

Amendment Nos.: 246 (Unit 1) and 250 (Unit 2).

Renewed Facility Operating License Nos. DPR-24 and DPR-27: Amendments revise the Renewed Facility Operating License and Technical Specifications.

Date of initial notice in Federal Register: May 17, 2011 (76 FR 28475).

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated January 30, 2012.

No significant hazards consideration comments received: No.

NextEra Energy Seabrook, LLC, Docket No. 50-443, Seabrook Station, Unit 1, Rockingham County, New Hampshire

Date of amendment request: July 14, 2011, as supplemented November 11, 2011.

Description of amendment request: The amendment replaces the Technical Specification surveillance 4.6.2.1.d 10-year surveillance frequency for testing the containment spray nozzles with an event-based frequency.

Date of issuance: January 30, 2012.

Effective date: As of its date of issuance and shall be implemented within 90 days.

Amendment No.: 128.

Facility Operating License No. NPF-86: The amendment revised the TS and the License.

Date of initial notice in Federal Register: September 6, 2011 (76 FR 55130).

The supplemental letter provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the U.S. Nuclear Regulatory Commission (NRC) staff's original proposed no significant hazards consideration determination.

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 30, 2012.

No significant hazards consideration comments received: No.

PSEG Nuclear LLC, Docket No. 50-354, Hope Creek Generating Station, Salem County, New Jersey

Date of application for amendment: February 28, 2011, as supplemented by letters dated August 29, and December 16, 2011, and January 26, 2012.

Brief description of amendments: The amendment modifies the Hope Creek Generating Station Technical Specifications (TSS) to revise the existing TS for the control room emergency filtration system and to add a new TS for the control room air conditioning system. The amendment is based, in part, on Nuclear Regulatory Commission-approved Technical Specification Task Force (TSTF) Standard TS Change Traveler TSTF-477, Revision 3, "Adding an Action Statement for Two Inoperable Control Room Air Conditioning Subsystems."

Date of issuance: February 8, 2012.

Effective date: As of the date of issuance, to be implemented within 60 days.

Amendment No.: 191.

Facility Operating License No. NPF-57: The amendment revised the TSs and the Facility Operating License.

Date of initial notice in Federal Register: May 3, 2011 (76 FR 24929).

The letters dated August 29, and December 16, 2011, and January 26, 2012, provided clarifying information that did not change the initial proposed no significant hazards consideration determination or expand the application.

The Commission's related evaluation of the amendments is contained in a Safety Evaluation dated February 8, 2012.

No significant hazards consideration comments received: No.

Yankee Atomic Electric Company, Docket No. 50-29, Yankee Nuclear Power Station, Franklin County, Massachusetts.

Date of application for amendment: August 10, 2011.

Brief Description of Amendment: The amendment revises License Condition C(3) "Physical Protection". It updates the title of the Physical Security Plan, from the "Yankee Nuclear Power Station Defueled Security Plan" Revision 0, dated October 13, 1992, and "Yankee Defueled Security Training and Qualification Plan" Revision 0, dated October 13, 1992, to the "Physical Security Plan for Yankee Rowe Independent Spent Fuel Storage Installation."

Amendment No.: 159.

Facility Operating License No. DPR-3. The amendment revised the Facility Operating License.

Date of Initial Notice in Federal Register. October 4, 2011 (76 FR 61398).

The Commission's related evaluation of the amendment is contained in a Safety Evaluation dated January 24, 2012.

No Significant Hazards Consideration Comments Received: No.

Dated at Rockville, Maryland, this 10th day of February 2012.

For the Nuclear Regulatory Commission.

Michele G. Evans,

Director, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation.

[FR Doc. 2012-3822 Filed 2-17-12; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

Advisory Committee on Reactor Safeguards (ACRS); Meeting of the ACRS Subcommittee on Reliability and PRA; Notice of Meeting

The ACRS Subcommittee on Reliability and PRA will hold a meeting on March 7, 2012, Room T-2B1, 11545 Rockville Pike, Rockville, Maryland.

The entire meeting will be open to public attendance.

The agenda for the subject meeting shall be as follows:

Wednesday, March 7, 2012—8:30 a.m. Until 5 p.m.

The Subcommittee will be briefed on the progress made for the tabletop exercises as part of the response to the SRM on SECY 10-0121, Modifying the Risk-Informed Regulatory Guidance For New Reactors. The Subcommittee will hear presentations by and hold discussions with the NRC staff and other interested persons regarding this matter. The Subcommittee will gather information, analyze relevant issues and facts, and formulate proposed positions and actions, as appropriate, for deliberation by the Full Committee.

Members of the public desiring to provide oral statements and/or written comments should notify the Designated Federal Official (DFO), John Lai (Telephone 301-415-5107 or Email: John.Lai@nrc.gov) five days prior to the meeting, if possible, so that appropriate arrangements can be made. Thirty-five hard copies of each presentation or handout should be provided to the DFO thirty minutes before the meeting. In addition, one electronic copy of each presentation should be emailed to the DFO one day before the meeting. If an electronic copy cannot be provided within this timeframe, presenters

should provide the DFO with a CD containing each presentation at least thirty minutes before the meeting. Electronic recordings will be permitted only during those portions of the meeting that are open to the public. Detailed procedures for the conduct of and participation in ACRS meetings were published in the **Federal Register** on October 17, 2011, (76 FR 64126-64127).

Detailed meeting agendas and meeting transcripts are available on the NRC Web site at <http://www.nrc.gov/reading-rm/doc-collections/acrs>. Information regarding topics to be discussed, changes to the agenda, whether the meeting has been canceled or rescheduled, and the time allotted to present oral statements can be obtained from the Web site cited above or by contacting the identified DFO.

Moreover, in view of the possibility that the schedule for ACRS meetings may be adjusted by the Chairman as necessary to facilitate the conduct of the meeting, persons planning to attend should check with these references if such rescheduling would result in a major inconvenience.

If attending this meeting, please enter through the One White Flint North building, 11555 Rockville Pike, Rockville, MD. After registering with security, please contact Mr. Theron Brown (240-888-9835) to be escorted to the meeting room.

Dated: February 14, 2012.

Antonio Dias,

Technical Advisor, Advisory Committee on Reactor Safeguards.

[FR Doc. 2012-3953 Filed 2-17-12; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

Sunshine Act Meeting

AGENCY HOLDING THE MEETINGS: Nuclear Regulatory Commission, [NRC-2012-0002].

DATE: Week of February 20, 2012.

PLACE: Commissioners' Conference Room, 11555 Rockville Pike, Rockville, Maryland.

STATUS: Public and Closed.

Additional Items To Be Considered

Week of February 20, 2012

Wednesday, February 22, 2012

8:55 a.m. Affirmation Session (Public Meeting) (Tentative).

a. *Entergy Nuclear Generation Co. and Entergy Nuclear Operations, Inc. (Pilgrim Nuclear Power Station),*