

acre impoundment with a 72-acre-foot storage capacity and a normal maximum water surface elevation of 631.79 feet msl; (4) a 28-foot-long, 36-foot-wide gatehouse; (5) a 30-foot-long, 16-foot-high gated intake structure; (6) one 7-foot-diameter, 150-foot-long buried steel penstock and one 10-foot-diameter, 150-foot-long buried, steel penstock; (7) a 54.5-foot-long, 30.5-foot-wide concrete-brick powerhouse containing a 600-kW turbine-generator unit and a 1,200-kW turbine-generator unit for a total installed capacity of 1,800 kW; (8) one 17.5-foot-long concrete-lined tailrace and one 14.0-foot-long concrete-lined tailrace; (9) a 435-foot-long, 34.5-kV transmission line connecting the powerhouse to the regional grid; and (10) appurtenant facilities.

The Morrisville Development bypasses approximately 380 feet of the Lamoille River.

Cadys Falls Development

The existing Cadys Falls Development is located on the Lamoille River approximately 1 mile downstream of the Morrisville Development and consists of: (1) A 364-foot-long, 41-foot-high concrete gravity dam comprised of a 23-foot-long embankment section, a 186-foot-long spillway section with 3.5-foot-high wooden flashboards and a crest elevation of 576.89 feet msl, a 60-foot-long intake and gatehouse section, and a 95-foot-long non-overflow section; (2) a 150-acre impoundment (Lake Lamoille) with a 72-acre-foot storage capacity and a normal maximum water surface elevation of 580.39 feet msl; (3) a 29-foot-long, 40-foot-wide gatehouse; (4) an 18.0-foot-long, 9.2-foot-high gated intake structure; (5) a buried, steel penstock that includes a 7-foot-diameter, 1,110-foot-long section leading to a 35.6-foot-high, 29.7-foot-diameter concrete surge tank and bifurcating into a 90-foot-long, 8-foot-diameter section and a 30-foot-long, 9-foot-diameter section; (6) a 96-foot-long, 46-foot-wide concrete-brick powerhouse containing a 600-kW turbine-generator unit and a 700-kW turbine-generator unit for a total installed capacity of 1,300 kW; (7) a 12-foot-long concrete-lined tailrace; (8) a 150-foot-long, 34.5-kV transmission line connecting the powerhouse to the regional grid; and (9) appurtenant facilities.

The Cadys Falls Development bypasses approximately 1,690 feet of the Lamoille River.

The Green River and Lake Elmore developments are operated in seasonal store and release mode and the Morrisville and Cadys Falls developments are operated in run-of-river mode. The existing license

requires instantaneous minimum flows of 5.5 cubic feet per second (cfs) in the tailrace of the Green River Development; 135 cfs and 12 cfs in the tailrace and bypassed reach of the Morrisville Development, respectively; and 150 cfs in the tailrace of the Cadys Falls Development. Morrisville proposes to maintain existing project operations and provide additional minimum flows of 4 cfs over the back spillway at the Morrisville Development and 12 cfs in the bypassed reach at the Cadys Falls Development. Morrisville also proposes to remove the Lake Elmore Development from the project and remove a 0.4-acre parcel of property at the Morrisville Development from the project boundary.

1. *Locations of the Application:* A copy of the application is available for review at the Commission in the Public Reference Room or may be viewed on the Commission's Web site at <http://www.ferc.gov> using the "eLibrary" link. Enter the docket number excluding the last three digits in the docket number field to access the document. For assistance, contact FERC Online Support at FERCOnlineSupport@ferc.gov or toll-free at 1-866-208-3676, or for TTY, (202) 502-8659. A copy is also available for inspection and reproduction at the address in item (h) above.

m. You may also register online at <http://www.ferc.gov/docs-filing/esubscription.asp> to be notified via email of new filings and issuances related to this or other pending projects. For assistance, contact FERC Online Support.

n. *Procedural Schedule:* The application will be processed according to the following preliminary Hydro Licensing Schedule. Revisions to the schedule may be made as appropriate.

Milestone	Target date
Notice of Acceptance/Notice of Ready for Environmental Analysis.	June 2013.
Filing of recommendations, preliminary terms and conditions, and fishway prescriptions.	August 2013.
Commission issues Non-Draft EA.	December 2013.
Comments on EA	January 2014.
Modified terms and conditions.	March 2014.

o. Final amendments to the application must be filed with the Commission no later than 30 days from the issuance date of the notice of ready for environmental analysis.

Dated: May 8, 2013.

Kimberly D. Bose,
Secretary.

[FR Doc. 2013-11640 Filed 5-15-13; 8:45 am]

BILLING CODE 6717-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

Notice of Application Accepted for Filing and Soliciting Motions To Intervene and Protests

	Project Nos.
Clean River Power MR-1, LLC	P-13404-002
Clean River Power MR-2, LLC	P-13405-002
Clean River Power MR-3, LLC	P-13406-002
Clean River Power MR-5, LLC	P-13407-002
Clean River Power MR-6, LLC	P-13408-002
Clean River Power MR-7, LLC	P-13411-002
Clean River Power MR-8, LLC	P-13412-002

Take notice that the following hydroelectric applications have been filed with the Commission and are available for public inspection.

a. *Type of Applications:* Original Major Licenses.

b. *Project Nos.:* 13404-002, 13405-002, 13406-002, 13407-002, 13408-002, 13411-002, and 13412-002.

c. *Date filed:* October 31, 2012.

d. *Applicants:* Clean River Power MR-1, LLC; Clean River Power MR-2, LLC; Clean River Power MR-3, LLC; Clean River Power MR-5, LLC; Clean River Power MR-6, LLC; Clean River Power MR-7, LLC; and Clean River Power MR-8, LLC (Clean River Power), subsidiaries of Free Flow Power Corporation.

e. *Name of Projects:* Beverly Lock and Dam Water Power Project, P-13404-002; Devola Lock and Dam Water Power Project, P-13405-002; Malta/McConnellsville Lock and Dam Water Power Project, P-13406-002; Lowell Lock and Dam Water Power Project, P-13407-002; Philo Lock and Dam Water Power Project, P-13408-002; Rokeby Lock and Dam Water Power Project, P-13411-002; and Zanesville Lock and Dam Water Power Project, P-13412-002.

f. *Locations:* At existing locks and dams on the Muskingum River in Washington, Morgan, and Muskingum counties, Ohio (see table below for specific project locations). The locks and dams were formally owned and

operated by the U.S. Army Corps of Engineers, but are now owned and operated by the Ohio Department of

Natural Resources, Division of Parks and Recreation.

Project No.	Projects	County(s)	City/town
P-13404-002	Beverly Lock and Dam	Washington and Morgan	Upstream of the City of Beverly, OH.
P-13405-002	Devola Lock and Dam	Washington	Near the City of Devola, OH.
P-13406-002	Malta/McConnelsville Lock and Dam	Morgan	On the southern shore of the Town of McConnelsville, OH.
P-13407-002	Lowell Lock and Dam	Washington	West of the City of Lowell, OH.
P-13408-002	Philo Lock and Dam	Muskingum	North of the City of Philo, OH.
P-13411-002	Rokeby Lock and Dam	Morgan and Muskingum	Near the City of Rokeby, OH.
P-13412-002	Zanesville Lock and Dam	Muskingum	Near the center of the City of Zanesville, OH.

g. *Filed Pursuant to:* Federal Power Act 16 U.S.C. 791 (a)-825(r).

h. *Applicant Contacts:* Ramya Swaminathan, Chief Operating Officer, Free Flow Power Corporation, 239 Causeway Street, Suite 300, Boston, MA 02114; or at (978) 283-2822.

Daniel Lissner, General Counsel, Free Flow Power Corporation, 239 Causeway Street, Suite 300, Boston, MA 02114; or at (978) 283-2822.

Alan Topalian, Regulatory Attorney, Free Flow Power Corporation, 239 Causeway Street, Suite 300, Boston, MA 02114; or at (978) 283-2822.

i. *FERC Contact:* Aaron Liberty at (202) 502-6862; or email at aaron.liberty@ferc.gov.

j. *Deadline for filing motions to intervene and protests:* 60 days from the issuance date of this notice.

All documents may be filed electronically via the Internet. See 18 CFR 385.2001(a)(1)(iii) and the instructions on the Commission's Web site <http://www.ferc.gov/docs-filing/efiling.asp>. Commenters can submit brief comments up to 6,000 characters, without prior registration, using the eComment system at <http://www.ferc.gov/docs-filing/ecomment.asp>. You must include your name and contact information at the end of your comments. For assistance, please contact FERC Online Support at FERCOnlineSupport@ferc.gov or toll free at 1-866-208-3676, or for TTY, (202) 502-8659. Although the Commission strongly encourages electronic filings, documents may also be paper-filed. To paper-file, mail an original and five copies to: Kimberly D. Bose, Secretary, Federal Energy Regulatory Commission, 888 First Street NE., Washington, DC 20426.

The Commission's Rules of Practice require all intervenors filing documents with the Commission to serve a copy of that document on each person on the official service list for the project. Further, if an intervenor files comments or documents with the Commission relating to the merits of an issue that

may affect the responsibilities of a particular resource agency, they must also serve a copy of the document on that resource agency.

k. These applications have been accepted for filing, but are not ready for environmental analysis at this time.

l. The proposed Zanesville Lock and Dam Project would be located at the existing Zanesville dam on the Muskingum River at RM 77.4. The Zanesville dam is a 513-foot-long, 18.8-foot-high dam that impounds a 470-acre reservoir at a normal pool elevation of 686.27 NAVD 88. The project would also consist of approximately 0.6 miles of the existing 59-foot-wide canal from the dam downstream to the proposed powerhouse and the following new facilities: (1) A 135-foot-long, 10-foot-high, 30-foot-wide intake structure with trash racks that contain 2-inch clear bar spacing; (2) two 10-foot diameter, 62-foot-long buried steel penstocks; (3) a 45-foot by 37-foot powerhouse located approximately 2,750 feet downstream of the dam on the bank of the canal; (4) two turbine-generator units providing a combined installed capacity of 2 MW; (5) a 31-foot-long, 37-foot-wide draft tube; (6) a 10-foot-long, 50-foot-wide tailrace; (7) a 40-foot by 40-foot substation; (8) a 400-foot-long, three-phase, overhead 69-kV transmission line to connect the project substation to the local utility distribution lines; and (9) appurtenant facilities. The average annual generation would be about 12,295 MWh.

The proposed Philo Lock and Dam Project would be located at the existing Philo dam on the Muskingum River at RM 68.6. The Philo dam is a 730-foot-long, 17-foot-high dam that impounds a 533-acre reservoir at a normal pool elevation of 671.39 NAVD 88. The applicant proposes to remove 128 feet of the existing dam to construct a 40-foot-long flap gate. The project would also consist of the following new facilities: (1) A 37-foot-long, 52-foot-high, 80-foot-wide intake structure with trash racks

that contain 2-inch clear bar spacing; (2) a 75-foot by 160-foot powerhouse located on the bank of the Muskingum River opposite the existing lock; (3) two turbine-generator units providing a combined installed capacity of 3 MW; (4) a 65-foot-long, 80-foot-wide draft tube; (5) a 140-foot-long, 180-foot-wide tailrace; (6) a 40-foot by 40-foot substation; (7) a 1,600-foot-long, three-phase, overhead 69-kV transmission line to connect the project substation to the local utility distribution lines; and (8) appurtenant facilities. The average annual generation would be about 15,957 MWh.

The proposed Rokeby Lock and Dam Project would be located at the existing Rokeby dam on the Muskingum River at RM 57.4. The Rokeby dam is a 525-foot-long, 20-foot-high dam that impounds a 615-acre reservoir at a normal pool elevation of 660.3 NAVD 88. The project would also consist of the following new facilities: (1) A 37-foot-long, 52-foot-high, 80-foot-wide intake structure with trash racks that contain 2-inch clear bar spacing; (2) a 75-foot by 160-foot powerhouse located on the bank of the Muskingum River opposite the existing lock; (3) two turbine-generator units providing a combined installed capacity of 4 MW; (4) a 65-foot-long, 75-foot-wide draft tube; (5) a 160-foot-long, 200-foot-wide tailrace; (6) a 40-foot by 40-foot substation; (7) a 490-foot-long, three-phase, overhead 69-kV transmission line to connect the project substation to the local utility distribution lines; and (8) appurtenant facilities. The average annual generation would be about 17,182 MWh.

The proposed Malta/McConnelsville Lock and Dam Project would be located at the existing Malta/McConnelsville dam on the Muskingum River at RM 49.4. The Malta/McConnelsville dam is a 605.5-foot-long, 15.2-foot-high dam that impounds a 442-acre reservoir at a normal pool elevation of 649.48 NAVD 88. The applicant proposes to remove 187.5 feet of the existing dam to

construct a 100-foot-long overflow weir. The project would also consist of the following new facilities: (1) a 37-foot-long, 52-foot-high, 80-foot-wide intake structure with trash racks containing 2-inch clear bar spacing; (2) a 80-foot by 160-foot powerhouse located adjacent to the right bank of the dam; (3) two turbine-generator units providing a combined installed capacity of 4.0 MW; (4) a 65-foot-long, 80-foot-wide draft tube; (5) a 100-foot-long, 130-foot-wide tailrace; (6) a 40-foot by 40-foot substation; (7) a 1,500-foot-long, three-phase, overhead 69-kV transmission line to connect the project substation to the local utility distribution lines; and (8) appurtenant facilities. The average annual generation would be about 21,895 MWh.

The proposed Beverly Lock and Dam Project would be located at the existing Beverly Lock and Dam on the Muskingum River at river mile (RM) 24.6. The Beverly dam is a 535-foot-long, 17-foot-high dam that impounds a 490-acre reservoir at a normal pool elevation of 616.36 North American Vertical Datum of 1988 (NAVD 88). The project would also consist of the following new facilities: (1) a 37-foot-long, 52-foot-high, 88-foot-wide intake structure with trash racks containing 2-inch clear bar spacing; (2) a 75-foot by 160-foot powerhouse located downstream of the dam on the left bank of the Muskingum River; (3) two turbine-generator units providing a combined installed capacity of 3.0 megawatts (MW); (4) a 65-foot-long, 75-foot-wide draft tube; (5) a 90-foot-long, 150-foot-wide tailrace; (6) a 40-foot by 40-foot substation; (7) a 970-foot-long, three-phase, overhead 69-kilovolt (kV) transmission line to connect the project substation to the local utility distribution lines; and (8) appurtenant facilities. The average annual generation would be about 17,853 megawatt-hours (MWh).

The proposed Lowell Lock and Dam Project would be located at the existing Lowell dam on the Muskingum River at RM 13.6. The Lowell dam is a 840-foot-long, 18-foot-high dam that impounds a 628-acre reservoir at a normal pool elevation of 607.06 NAVD 88. The applicant proposes to remove 204 feet of the existing dam to construct a 143.5-foot-long overflow weir. The project would also consist of the following new facilities: (1) A 37-foot-long, 23-foot-high, 80-foot-wide intake structure with trash racks that contain 2-inch clear bar spacing; (2) a 75-foot by 160-foot powerhouse located adjacent to the left bank of the dam; (3) two turbine-generator units providing a combined installed capacity of 5 MW; (4) a 65-

foot-long, 75-foot-wide draft tube; (5) a 100-foot-long, 125-foot-wide tailrace; (6) a 40-foot by 40-foot substation; (7) a 1,200-foot-long, three-phase, overhead 69-kV transmission line to connect the project substation to the local utility distribution lines; and (8) appurtenant facilities. The average annual generation would be about 30,996 MWh.

The proposed Devola Lock and Dam Project would be located at the existing Devola Lock and Dam on the Muskingum River at RM 5.8. The Devola dam is a 587-foot-long, 17-foot-high dam that impounds a 301-acre reservoir at a normal pool elevation of 592.87 NAVD 88. The applicant proposes to remove 187 feet of the existing dam to construct a 154-foot-long overflow weir. The project would also consist of the following new facilities: (1) A 37-foot-long, 52-foot-high, 80-foot-wide intake structure with trash racks containing 2-inch clear bar spacing; (2) a 80-foot by 160-foot powerhouse located on the bank of the Muskingum River opposite the existing lock; (3) two turbine-generator units providing a combined installed capacity of 4.0 MW; (4) a 65-foot-long, 80-foot-wide draft tube; (5) a 125-foot-long, 140-foot-wide tailrace; (6) a 40-foot by 40-foot substation; (7) a 3,600-foot-long, three-phase, overhead 69-kV transmission line to connect the project substation to the local utility distribution lines; and (8) appurtenant facilities. The average annual generation would be about 20,760 MWh.

The applicant proposes to operate all seven projects in a run-of-river mode, such that the water surface elevations within each project impoundment would be maintained at the crest of each respective dam spillway.

m. A copy of the applications are available for review at the Commission in the Public Reference Room or may be viewed on the Commission's Web site at <http://www.ferc.gov> using the "eLibrary" link. Enter the docket number excluding the last three digits in the docket number field to access the document. For assistance, contact FERC Online Support. Copies are also available for inspection and reproduction at the address in item h above.

Register online at <http://www.ferc.gov/docs-filing/esubscription.asp> to be notified via email of new filings and issuances related to these or other pending projects. For assistance, contact FERC Online Support.

n. Any qualified applicant desiring to file a competing application must submit to the Commission, on or before the specified intervention deadline date, a competing development application,

or a notice of intent to file such an application. Submission of a timely notice of intent allows an interested person to file the competing development application no later than 120 days after the specified intervention deadline date. Applications for preliminary permits will not be accepted in response to this notice.

A notice of intent must specify the exact name, business address, and telephone number of the prospective applicant, and must include an unequivocal statement of intent to submit a development application. A notice of intent must be served on the applicant(s) named in this public notice.

Anyone may submit comments, a protest, or a motion to intervene in accordance with the requirements of Rules of Practice and Procedure, 18 CFR 385.210, 385.211, and 385.214. In determining the appropriate action to take, the Commission will consider all protests or other comments filed, but only those who file a motion to intervene in accordance with the Commission's Rules may become a party to the proceeding. Any protests or motions to intervene must be received on or before the specified deadline for the particular application.

When the applications are ready for environmental analysis, the Commission will issue a public notice requesting comments, recommendations, terms and conditions, or prescriptions.

All filings must (1) bear in all capital letters the title "PROTEST" or "MOTION TO INTERVENE," "NOTICE OF INTENT TO FILE COMPETING APPLICATION," or "COMPETING APPLICATION;" (2) set forth in the heading the name of the applicant and the project number of the application to which the filing responds; (3) furnish the name, address, and telephone number of the person protesting or intervening; and (4) otherwise comply with the requirements of 18 CFR 385.2001 through 385.2005. Agencies may obtain copies of the applications directly from the applicant. A copy of any protest or motion to intervene must be served upon each representative of the applicant specified in the particular application.

Dated: May 8, 2013.

Kimberly D. Bose,
Secretary.

[FR Doc. 2013-11667 Filed 5-15-13; 8:45 am]

BILLING CODE 6717-01-P