

The design function of the Turbine Building (TB) is to provide weather protection for the laydown and maintenance of major turbine/generator components. The TB first bay is a seismic Category II structure designed to prevent the collapse under a safe shutdown earthquake (SSE) to protect the adjacent auxiliary building. The electrical system and air-handling units are designed to provide electrical power to plant loads and maintain acceptable temperatures for electrical equipment rooms and work areas. The electrical equipment continues to be in accordance with the same codes and standards stated in the Updated Final Safety Analysis Report (UFSAR). The proposed relocation of equipment, including the increase in floor elevation by 10 inches to accommodate overhead equipment cabling, does not impact the TB design function. The TB first bay continues to meet seismic Category II requirements. Based on this, the proposed changes would not increase the probability of an accident previously evaluated.

The proposed changes do not involve any accident initiating event, thus the probabilities of the accidents previously evaluated are not affected. The relocation of equipment does not involve any safety-related structures, systems, or components; the affected rooms do not represent a radioactive material barrier; and this activity does not affect the containment of radioactive material. The radioactive material source terms and release paths used in the safety analyses are unchanged, thus the radiological releases in the accident analyses are not affected. Therefore, the consequences of an accident previously evaluated are not affected.

Therefore, there is no significant increase in the probability or consequences of an accident previously evaluated.

2. Does the proposed amendment create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No.

The proposed changes would use the same type of electrical equipment with higher ratings and capacity, change the source of a battery back-up, and relocate equipment. The electrical equipment will continue to perform its design functions because the same electrical codes and standards as stated in the UFSAR continue to be met. Therefore the proposed changes do not affect equipment failure probabilities or alter any accident initiator or initiating sequence of events. The proposed changes in location of equipment and elevation of the TB first bay floor do not affect the design function of the TB first bay to protect the adjacent auxiliary building by meeting seismic Category II structure requirements, or affect the operation of the relocated equipment, or the ability of the relocated equipment to meet its design functions. Because the SSCs and equipment affected by the proposed changes continue to meet their design functions, the structural codes and standards as stated in the UFSAR, the proposed changes do not introduce a different type of accident than those previously considered.

Therefore, this activity does not create the possibility of a new or different kind of

accident from any accident previously evaluated.

3. Does the proposed amendment involve a significant reduction in a margin of safety?

Response: No.

The current seismic requirements applicable to the seismic Category II TB first bay structure, including the seismic modeling and analysis methods, will continue to apply to the TB first bay floor elevation increase. The proposed changes to relocate equipment and the increase in the floor elevation will continue to meet the fire rating requirements and will be in accordance with the same codes and standards currently identified in the UFSAR. The proposed changes to the electrical equipment will continue to meet existing electrical equipment industry standard recommendations identified in the UFSAR. Because no safety analysis or design basis acceptance limit/criterion is challenged or exceeded by these proposed changes, no margin of safety is reduced.

Therefore, the changes do not involve a significant reduction in a margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the amendment request involves no significant hazards consideration.

Attorney for licensee: Ms. Kathryn M. Sutton, Morgan, Lewis & Bockius LLC, 1111 Pennsylvania Avenue NW., Washington, DC 20004-2514.

NRC Branch Chief: Lawrence Burkhardt.

Dated at Rockville, Maryland, this 15th day of November 2013.

For the Nuclear Regulatory Commission.

Michele G. Evans,

Director, Division of Operating Reactor Licensing, Office of Nuclear Reactor Regulation.

[FR Doc. 2013-28225 Filed 11-25-13; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

Advisory Committee on Reactor Safeguards (ACRS) Meeting of the ACRS Subcommittee on Power Upgrades; Notice of Meeting

The ACRS Subcommittee on Power Upgrades will hold a meeting on December 3, 2013, Room T-2B3, 11545 Rockville Pike, Rockville, Maryland.

The meeting will be open to public attendance with the exception of a portion that may be closed to protect information that is proprietary pursuant to 5 U.S.C. 552b(c)(4). The agenda for the subject meeting shall be as follows:

Tuesday, December 3, 2013—8:30 a.m. Until 5:00 p.m.

The Subcommittee will review the Monticello Maximum Extended Load Line Limit Analysis plus license amendment request. The Subcommittee will hear presentations by and hold discussions with the licensee, (Northern States Power Company of Minnesota), the NRC staff, and other interested persons regarding this matter. The Subcommittee will gather information, analyze relevant issues and facts, and formulate proposed positions and actions, as appropriate, for deliberation by the Full Committee.

Members of the public desiring to provide oral statements and/or written comments should notify the Designated Federal Official (DFO), Peter Wen (Telephone 301-415-2832 or Email: Peter.Wen@nrc.gov) five days prior to the meeting, if possible, so that appropriate arrangements can be made. Thirty-five hard copies of each presentation or handout should be provided to the DFO thirty minutes before the meeting. In addition, one electronic copy of each presentation should be emailed to the DFO one day before the meeting. If an electronic copy cannot be provided within this timeframe, presenters should provide the DFO with a CD containing each presentation at least thirty minutes before the meeting. Electronic recordings will be permitted only during those portions of the meeting that are open to the public. Detailed procedures for the conduct of and participation in ACRS meetings were published in the **Federal Register** on November 8, 2013 (78 CFR 67205-67206).

Detailed meeting agendas and meeting transcripts are available on the NRC Web site at <http://www.nrc.gov/reading-rm/doc-collections/acrs>. Information regarding topics to be discussed, changes to the agenda, whether the meeting has been canceled or rescheduled, and the time allotted to present oral statements can be obtained from the Web site cited above or by contacting the identified DFO. Moreover, in view of the possibility that the schedule for ACRS meetings may be adjusted by the Chairman as necessary to facilitate the conduct of the meeting, persons planning to attend should check with these references if such rescheduling would result in a major inconvenience.

If attending this meeting, please enter through the One White Flint North building, 11555 Rockville Pike, Rockville, MD. After registering with security, please contact Mr. Theron

Brown (Telephone 240-888-9835) to be escorted to the meeting room.

Dated: November 13, 2013.

Cayetano Santos,

Chief, Technical Support Branch, Advisory Committee on Reactor Safeguards.

[FR Doc. 2013-28358 Filed 11-25-13; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

Advisory Committee on Reactor Safeguards (ACRS) Meeting of the ACRS Subcommittee on Planning and Procedures; Notice of Meeting

The ACRS Subcommittee on Planning and Procedures will hold a meeting on December 4, 2013, Room T-2B3, 11545 Rockville Pike, Rockville, Maryland.

The meeting will be open to public attendance with the exception of a portion that may be closed pursuant to 5 U.S.C. 552b (c)(2) and (6) to discuss organizational and personnel matters that relate solely to the internal personnel rules and practices of the ACRS, and information the release of which would constitute a clearly unwarranted invasion of personal privacy.

The agenda for the subject meeting shall be as follows:

Wednesday, December 4, 2013—12:00 p.m. Until 1:00 p.m.

The Subcommittee will discuss proposed ACRS activities and related matters. The Subcommittee will gather information, analyze relevant issues and facts, and formulate proposed positions and actions, as appropriate, for deliberation by the Full Committee.

Members of the public desiring to provide oral statements and/or written comments should notify the Designated Federal Official (DFO), Quynh Nguyen (Telephone 301-415-5844 or Email: Quynh.Nguyen@nrc.gov) five days prior to the meeting, if possible, so that arrangements can be made. Thirty-five hard copies of each presentation or handout should be provided to the DFO thirty minutes before the meeting. In addition, one electronic copy of each presentation should be emailed to the DFO one day before the meeting. If an electronic copy cannot be provided within this timeframe, presenters should provide the DFO with a CD containing each presentation at least thirty minutes before the meeting. Electronic recordings will be permitted only during those portions of the meeting that are open to the public. Detailed procedures for the conduct of and participation in ACRS meetings

were published in the **Federal Register** on November 8, 2013 (78 CFR 67205-67206).

Information regarding changes to the agenda, whether the meeting has been canceled or rescheduled, and the time allotted to present oral statements can be obtained by contacting the identified DFO. Moreover, in view of the possibility that the schedule for ACRS meetings may be adjusted by the Chairman as necessary to facilitate the conduct of the meeting, persons planning to attend should check with the DFO if such rescheduling would result in a major inconvenience.

If attending this meeting, please enter through the One White Flint North building, 11555 Rockville Pike, Rockville, MD. After registering with security, please contact Mr. Theron Brown (240-888-9835) to be escorted to the meeting room.

Dated: November 13, 2013.

Cayetano Santos,

Chief, Technical Support Branch, Advisory Committee on Reactor Safeguards.

[FR Doc. 2013-28327 Filed 11-25-13; 8:45 am]

BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

Advisory Committee on Reactor Safeguards (ACRS); Meeting of the ACRS Subcommittee on Radiation Protection and Nuclear Materials; Notice of Meeting

The ACRS Subcommittee on Radiation Protection and Nuclear Materials will hold a meeting on December 3, 2013, Room T-2B1, 11545 Rockville Pike, Rockville, Maryland.

The meeting will be open to public attendance.

The agenda for the subject meeting shall be as follows:

Tuesday, December 3, 2013—8:30 a.m. Until 5:00 p.m.

The Subcommittee will review and discuss Part 61 rulemaking revisions and technical justifications. The Subcommittee will hear presentations by and hold discussions with representatives of Agreement States, low-level radioactive waste disposal facilities, industry groups, and other interested persons regarding this matter. The Subcommittee will gather information, analyze relevant issues and facts, and formulate proposed positions and actions, as appropriate, for deliberation by the Full Committee.

Members of the public desiring to provide oral statements and/or written comments should notify the Designated

Federal Official (DFO), Derek Widmayer (Telephone 301-415-7366 or Email: Derek.Widmayer@nrc.gov) five days prior to the meeting, if possible, so that appropriate arrangements can be made. Thirty-five hard copies of each presentation or handout should be provided to the DFO thirty minutes before the meeting. In addition, one electronic copy of each presentation should be emailed to the DFO one day before the meeting. If an electronic copy cannot be provided within this timeframe, presenters should provide the DFO with a CD containing each presentation at least thirty minutes before the meeting. Electronic recordings will be permitted only during those portions of the meeting that are open to the public. Detailed procedures for the conduct of and participation in ACRS meetings were published in the **Federal Register** on November 8, 2013 (78 CFR 67205-67206).

Detailed meeting agendas and meeting transcripts are available on the NRC Web site at <http://www.nrc.gov/reading-rm/doc-collections/acrs>. Information regarding topics to be discussed, changes to the agenda, whether the meeting has been canceled or rescheduled, and the time allotted to present oral statements can be obtained from the Web site cited above or by contacting the identified DFO. Moreover, in view of the possibility that the schedule for ACRS meetings may be adjusted by the Chairman as necessary to facilitate the conduct of the meeting, persons planning to attend should check with these references if such rescheduling would result in a major inconvenience.

If attending this meeting, please enter through the One White Flint North building, 11555 Rockville Pike, Rockville, MD. After registering with security, please contact Mr. Theron Brown (Telephone 240-888-9835) to be escorted to the meeting room.

Dated: November 20, 2013.

Cayetano Santos,

Chief, Technical Support Branch, Advisory Committee on Reactor Safeguards.

[FR Doc. 2013-28328 Filed 11-25-13; 8:45 am]

BILLING CODE 7590-01-P