

low enriched uranium, 61,535 g of which is in the isotope of U-235 (12.12 percent enrichment), and 4,427 g of plutonium, in the form of 236 irradiated fuel assemblies from the Open Pool Australian Lightwater (OPAL) research reactor at the Australian Nuclear Science and Technology Organisation in Australia, to Orano (formerly AREVA NC) at the La Hague reprocessing plant in France. The material in the irradiated fuel assemblies, which is currently located at the OPAL reactor, is to be retransferred to the La Hague plant for reprocessing. Orano will take title to the plutonium recovered during reprocessing, which will be incorporated into fresh civilian mixed oxide fuel assemblies. Residual plutonium that is not removed during reprocessing will be vitrified in canisters, which will be returned to Australia at a later time.

In accordance with section 131 of the Atomic Energy Act of 1954, as amended, I have determined that this subsequent arrangement concerning the retransfer of U.S.-obligated special nuclear material for reprocessing will not be inimical to the common defense and security of the United States of America and made the judgment that it will not result in a significant increase in the risk of proliferation beyond that which exists now, or which existed at the time approval was requested.

Dated: April 10, 2018.

For the Department of Energy.

Lisa E. Gordon-Hagerty,

Under Secretary for Nuclear Security Administrator, National Nuclear Security Administration.

[FR Doc. 2018-08284 Filed 4-19-18; 8:45 am]

BILLING CODE 6450-01-P

DEPARTMENT OF ENERGY

DOE/NSF High Energy Physics Advisory Panel

AGENCY: Office of Science, Department of Energy.

ACTION: Notice of open meeting.

SUMMARY: This notice announces a meeting of the DOE/NSF High Energy Physics Advisory Panel (HEPAP). The Federal Advisory Committee Act requires that public notice of these meetings be announced in the **Federal Register**.

DATES: Monday, May 14, 2018, 8:30 a.m. to 6:00 p.m.; Tuesday, May 15, 2018, 8:30 a.m. to 4:00 p.m.

ADDRESSES: Hilton Washington DC North/Gaithersburg, 620 Perry Parkway, Gaithersburg, MD 20877.

FOR FURTHER INFORMATION CONTACT: John Kogut, Executive Secretary; High Energy Physics Advisory Panel (HEPAP); U.S. Department of Energy; Office of Science; SC-25/Germantown Building, 1000 Independence Avenue SW, Washington, DC 20585; Telephone: (301) 903-1298.

SUPPLEMENTARY INFORMATION:

Purpose of Meeting: To provide advice and guidance on a continuing basis to the Department of Energy and the National Science Foundation on scientific priorities within the field of high energy physics research.

Tentative Agenda: Agenda will include discussions of the following: May 14-15, 2018.

- Discussion of Department of Energy High Energy Physics Program
- Discussion of National Science Foundation Elementary Particle Physics Program
- Reports on and Discussions of Topics of General Interest in High Energy Physics
- Public Comment (10-minute rule)

Public Participation: The meeting is open to the public. A webcast of this meeting will be available. Please check the website below for updates and information on how to view the meeting. If you would like to file a written statement with the Committee, you may do so either before or after the meeting. If you would like to make oral statements regarding any of these items on the agenda, you should contact John Kogut, (301) 903-1298 or by email at: John.Kogut@science.doe.gov. You must make your request for an oral statement at least five business days before the meeting. Reasonable provision will be made to include the scheduled oral statements on the agenda. The Chairperson of the Panel will conduct the meeting to facilitate the orderly conduct of business. Public comment will follow the 10-minute rule.

Minutes: The minutes of the meeting will be available on the U.S. Department of Energy's Office of High Energy Physics Advisory Panel website: <http://science.energy.gov/hep/hepap/meetings/>.

Issued at Washington, DC, on April 16, 2018.

Latanya Butler,

Deputy Committee Management Officer.

[FR Doc. 2018-08242 Filed 4-19-18; 8:45 am]

BILLING CODE 6450-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

[Docket No. ER18-1343-000]

Carolina Solar Power, LLC; Supplemental Notice That Initial Market-Based Rate Filing Includes Request for Blanket Section 204 Authorization

This is a supplemental notice in the above-referenced proceeding Carolina Solar Power, LLC's application for market-based rate authority, with an accompanying rate tariff, noting that such application includes a request for blanket authorization, under 18 CFR part 34, of future issuances of securities and assumptions of liability.

Any person desiring to intervene or to protest should file with the Federal Energy Regulatory Commission, 888 First Street NE, Washington, DC 20426, in accordance with Rules 211 and 214 of the Commission's Rules of Practice and Procedure (18 CFR 385.211 and 385.214). Anyone filing a motion to intervene or protest must serve a copy of that document on the Applicant.

Notice is hereby given that the deadline for filing protests with regard to the applicant's request for blanket authorization, under 18 CFR part 34, of future issuances of securities and assumptions of liability, is May 7, 2018.

The Commission encourages electronic submission of protests and interventions in lieu of paper, using the FERC Online links at <http://www.ferc.gov>. To facilitate electronic service, persons with internet access who will eFile a document and/or be listed as a contact for an intervenor must create and validate an eRegistration account using the eRegistration link. Select the eFiling link to log on and submit the intervention or protests.

Persons unable to file electronically should submit an original and 5 copies of the intervention or protest to the Federal Energy Regulatory Commission, 888 First Street NE, Washington, DC 20426.

The filings in the above-referenced proceeding are accessible in the Commission's eLibrary system by clicking on the appropriate link in the above list. They are also available for electronic review in the Commission's Public Reference Room in Washington, DC. There is an eSubscription link on the website that enables subscribers to receive email notification when a document is added to a subscribed docket(s). For assistance with any FERC Online service, please email

FERCOnlineSupport@ferc.gov, or call (866) 208-3676 (toll free). For TTY, call (202) 502-8659.

Dated: April 16, 2018.

Nathaniel J. Davis, Sr.,
Deputy Secretary.

[FR Doc. 2018-08307 Filed 4-19-18; 8:45 am]

BILLING CODE 6717-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

[Project No. 2788-017]

Notice of Application Ready for Environmental Analysis and Soliciting Comments, Recommendations, Terms and Conditions, and Prescriptions; Goodyear Lake Hydro, LLC

Take notice that the following hydroelectric application has been filed with the Commission and is available for public inspection.

- a. *Type of Application*: Subsequent Minor License.
- b. *Project No.*: 2788-017.
- c. *Date filed*: February 27, 2017.
- d. *Applicant*: Goodyear Lake Hydro, LLC (Goodyear Lake Hydro).
- e. *Name of Project*: Colliersville Hydroelectric Project.
- f. *Location*: On the Susquehanna River, in the Town of Milford, Otsego County, New York. The project does not occupy lands of the United States.
- g. *Filed Pursuant to*: Federal Power Act 16 U.S.C. 791 (a)-825(r).
- h. *Applicant Contact*: Mr. Kevin Webb, Hydro Licensing Manager; Enel Green Power North America, Inc., 100 Brickstone Square, Suite 300, Andover, MA 01810; (978) 935-6039; kevin.webb@enel.com.

i. *FERC Contact*: Emily Carter, (202) 502-6512 or emily.carter@ferc.gov.

j. *Deadline for filing comments, recommendations, terms and conditions, and prescriptions*: 60 days from the issuance date of this notice; reply comments are due 105 days from the issuance date of this notice.

The Commission strongly encourages electronic filing. Please file comments, recommendations, terms and conditions, and prescriptions using the Commission's eFiling system at <http://www.ferc.gov/docs-filing/efiling.asp>. Commenters can submit brief comments up to 6,000 characters, without prior registration, using the eComment system

at <http://www.ferc.gov/docs-filing/ecomment.asp>. You must include your name and contact information at the end of your comments. For assistance, please contact FERC Online Support at FERCOnlineSupport@ferc.gov, (866) 208-3676 (toll free), or (202) 502-8659 (TTY). In lieu of electronic filing, please send a paper copy to: Secretary, Federal Energy Regulatory Commission, 888 First Street NE, Washington, DC 20426. The first page of any filing should include docket number P-2788-017.

The Commission's Rules of Practice require all intervenors filing documents with the Commission to serve a copy of that document on each person on the official service list for the project. Further, if an intervenor files comments or documents with the Commission relating to the merits of an issue that may affect the responsibilities of a particular resource agency, they must also serve a copy of the document on that resource agency.

k. This application has been accepted, and is ready for environmental analysis at this time.

l. *The Colliersville Hydroelectric Project consists of*: (1) A 200-foot-long, 35-foot-high reinforced-concrete Ambursen-type dam; (2) a 364-acre reservoir (Goodyear Lake) with a gross storage capacity of 7,800 acre-feet at a normal pool elevation of 1,150.22 feet National Geodetic Vertical Datum of 1929; (3) a 550-foot-long reinforced concrete power canal, approximately 50 feet wide and 6 feet deep at the head gates, extending from a head gate structure adjacent to the dam (*i.e.*, the intake) to the powerhouse; (4) a 103-foot-long by 33-foot-wide reinforced concrete powerhouse with trash racks with a clear spacing of 1.5 inches, and containing two turbines rated at 850 horsepower (HP) and 1,150 HP, and two generators having a rated capacity of 650 kilowatts (kW) and 850 kW, respectively; (5) a 300-foot-long and approximately 50- to 60-foot-wide tailrace; (6) approximately 80-foot-long, 4.16-kilovolt underground generator leads or transmission lines from the powerhouse to an adjacent substation owned by the New York State Electric and Gas Corporation; and (7) appurtenant facilities.

Goodyear Lake Hydro operates the project in a run-of-river mode. The project experiences substantial seasonal and annual variations in generation, and generates an annual average of 5,985

megawatt-hours. Goodyear Lake Hydro proposes to continue to operate the project in run-of-river mode.

m. A copy of the application is available for review at the Commission in the Public Reference Room or may be viewed on the Commission's website at <http://www.ferc.gov> using the eLibrary link. Enter the docket number excluding the last three digits in the docket number field to access the document. For assistance, contact FERC Online Support. A copy is also available for inspection and reproduction at the address in item h above.

All filings must (1) bear in all capital letters the title COMMENTS, REPLY COMMENTS, RECOMMENDATIONS, TERMS AND CONDITIONS, or PRESCRIPTIONS; (2) set forth in the heading the name of the applicant and the project number of the application to which the filing responds; (3) furnish the name, address, and telephone number of the person submitting the filing; and (4) otherwise comply with the requirements of 18 CFR 385.2001 through 385.2005. All comments, recommendations, terms and conditions or prescriptions must set forth their evidentiary basis and otherwise comply with the requirements of 18 CFR 4.34(b). Agencies may obtain copies of the application directly from the applicant. Each filing must be accompanied by proof of service on all persons listed on the service list prepared by the Commission in this proceeding, in accordance with 18 CFR 4.34(b) and 385.2010.

You may also register online at <http://www.ferc.gov/docs-filing/esubscription.asp> to be notified via email of new filings and issuances related to this or other pending projects. For assistance, contact FERC Online Support.

n. *A license applicant must file no later than 60 days following the date of issuance of this notice*: (1) A copy of the water quality certification; (2) a copy of the request for certification, including proof of the date on which the certifying agency received the request; or (3) evidence of waiver of water quality certification.

o. *Procedural schedule*: The application will be processed according to the following schedule. Revisions to the schedule will be made as appropriate.

Milestone	Target date
Deadline for Filing Comments, Recommendations, and Agency Terms and Conditions/Prescriptions	June 2018.
Deadline for filing Reply Comments	July 2018.
Commission issues EA	November 2018.